



Burlington, WA	Corporate/Laboratory (a)	1633 S Walnut St	Burlington, WA 98233	800.755.8285 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr. Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (a)	8150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (a)	540 SW Third Street	Corvallis, OR 97339	541.753.4846




INORGANIC COMPOUNDS (IOC) REPORT

Client Name: Hat Island Community
 3616 Colby Ave PMB 335
 Everett, WA 98201

Reference Number: 17-22380
Project: SHD-WWW-Hat Island

System Name: HAT ISLAND COMMUNITY INC
System ID Number: 31593N
DOH Source Number: 507 well 1, 2, 3, 5, 6 CI/10-2-17
Multiple Sources:
Sample Type: A - After treatment
Sample Purpose: C - Compliance
Sample Location: G-Tank Pumphouse (Pre-Distribution)
County: Snohomish

Sample Number: 1040152151
Lab Number: 046-49650
Collect Date: 8/29/17 11:00
Date Received: 8/30/17
Report Date: 9/6/17
Sampled By: Chris Inman
Sampler Phone: 206-283-6443G
Approved by: amp
Authorized by:


 Lawrence J Henderson, PhD
 Director of Laboratories, Vice President

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
4	EPA Regulated ARSENIC	0.005	mg/L	0.001		0.010	bj	200.3	a	09/05/17	

NOTES:
 SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).
 MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.
 Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.
 ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).
 (a) in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.
 If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above.