



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946



FL NELAP E871040

INORGANIC COMPOUNDS (IOC) REPORT

Client Name: Hat Island Community
3616 Colby Ave - Box 335
Everett, WA 98201

Reference Number: 17-29514
Project: SHD-WWW - Hat Island Commun

System Name: HAT ISLAND COMMUNITY INC
System ID Number: 31593N
DOH Source Number: 07

Sample Number: 1040159013
Lab Number: 046-64146
Collect Date: 10/18/17 18:00

Multiple Sources:
Sample Type: D - Drinking Water
Sample Purpose: C - Compliance
Sample Location: Hat Island
County: SNOHOMISH

Date Received: 10/19/17
Report Date: 10/25/17
Sampled By: Chris Inman
Sampler Phone: 360.444.6611
Approved by: anp
Authorized by:

JH
Lawrence J Henderson, PhD
Director of Laboratories, Vice President

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
4	EPA Regulated ARSENIC	0.006	mg/L	0.001		0.010	bj	200.8	a	10/24/17	

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).
MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.
Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.
ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).
An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above.