




Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946



INORGANIC COMPOUNDS (IOC) REPORT

Client Name: **Hat Island Community**
 3616 Colby Ave. PMB 335
 Everett, WA 98201

Reference Number: 18-18633
 Project: SHD-WWW - Hat Island Commun

Date Collected: 5/24/18 13:00
 System ID Number: **PWS ID**
 Lab Number: **046-38258**
 Sample Location: G Tank Pump House
 Sample Purpose: R - Repeat
 Sample Composition:
 Approved by: anp
 Authorized by: 
 Lawrence J Henderson, PhD
 Director of Laboratories, Vice President

Field ID: 1040163000
 System Group Type: A
 System Name: SYSTEM NAME
 County: County
 Source Number: **Source Number**
 Multiple Sources: Multiple Sources
 Date Received: 5/25/18
 Report Date: 6/11/18
 Sample Type:
 Sampled By: CHRIS INMAN
 Sampler Phone: Sampler Phone

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
4	EPA Regulated ARSENIC	0.003	mg/L	0.001		0.010	bj	200.8	a	06/07/18	

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).
 MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.
 Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.
 ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).
 An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.
 If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above.