



Burlington WA 1620 S Walnut St - 98233
 Corporate Office 800.755.9295 • 360.757.1400 • 360.757.1402fax
 Bellingham WA 805 Orchard Dr Suite 4 - 98225
 Microbiology 360.671.0688 • 360.671.1577fax

Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Hat Island Community Inc
 3616 Colby Ave
 Everett, WA 98201

Reference Number: 10-00658
 Project: SHD-WWW - Hat Island Bacter

System Name: HAT ISLAND COMMUNITY INC
 System ID 31593N
 DOH Source Number: 00 - Distribution Sample (Bacteria)
 Sample Type: D - Drinking Water
 Sample Purpose: C - Compliance
 Sample Location: E-17
 County: Snohomish
 Sampled By: Wayne Orff
 Sampler Phone:

Repeat Sample Number:
 Lab Number: 164-01485
 Field ID: 1040064224
 Date Collected: 1/13/10 08:05
 Date Received: 1/14/10
 Date Analyzed: 1/15/10 09:18
 Report Date: 1/15/10
 Comment: CI2:0.40
 Peer Review:

DOH#	PARAMETER	RESULT	UNITS	Analyst	METHOD	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent	per 100mL	ms	SM9223 B	
3	E. COLI	Absent	per 100mL		SM9223 B	
				JAN 20 REC'D		

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: <http://www.skagitcounty.net/drinkingwater> or 360-336-9380
- Snohomish Co: 425-339-5250
- Whatcom Co: http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

NOTES:
 If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.
 If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.