



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946


Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: **Hat Island Community**
3616 Colby Ave - Box 335
Everett, WA 98201

Reference Number: 17-14983
Project: SHD-WWW - Hat Island
Community Water

System Name: HAT ISLAND COMMUNITY INC
System ID Number: 31593N
DOH Source Number: 00 - Distribution Sample (Bacteria)
Sample Type: D - Drinking Water
Sample Purpose: C - Compliance
Sample Location: M38
County: Snohomish
Sampled By: Chris Inman
Sampler Phone: 360-444-6611

Repeat Sample Number:
Lab Number: 164-34437
Field ID: 1040151956
Date Collected: 6/25/17 18:00
Date Received: 6/26/17
Date Set: 6/26/17 16:58
Date Analyzed: 6/27/17 11:23
Report Date: 6/27/17
Comment:
Approved By: ckk,clh

Authorized by: 
Cynthia L Hansen
Lab Manager

DOH#	PARAMETER	RESULT	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent	per 100mL	sms	SM9223 B	m_170626	
3	E. COLI	Absent	per 100mL		SM9223 B	m_170626	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: http://www.skagitcounty.net/drinkingwater_ or 360-336-9380
- Snohomish Co: 425-339-5250
- Whatcom Co: http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

NOTES:

If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.
If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.