



Burlington, WA *Corporate Laboratory (a)*  
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400  
 Bellingham, WA *Microbiology (b)*  
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR *Microbiology/Chemistry (c)*  
 9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802  
 Corvallis, OR *Microbiology/Chemistry (d)*  
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946  
 Bend, OR *Microbiology (e)*  
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



OR NELAP 4072  
 Page 1 of 1

## LEAD & COPPER RULE REPORT

Client Name: **Hat Island Community**  
 3616 Colby Ave #335  
 Everett, WA 98201

Reference Number: **23-22434**

Project: **Lead and Copper**

System ID Number: **31593N**  
 Lab Number: **046-44465**  
 Sample Purpose: **C - Compliance**  
 Sample Composition: **Single Source**

System Group Type: **A**  
 System Name: **HAT ISLAND COMMUNITY INC**  
 County: **SNOHOMISH**  
 Source Number: **93 - Standing Water (Pb&Cu)**  
 Multiple Sources:

Approved By: **bj**

Authorized By:

Lawrence J Henderson, PhD  
 Director of Laboratories, Vice President

Date Received: **7/27/2023**

Date Reported: **8/1/23**

Sample Type: **A - After treatment**

Lab Number	Date Collected	Site / Location	PRM #	Analyte Name	Result	Units	AL	SRL	METHOD	Lab	Analyzed	Comments
046-44465	7/26/2023	31593N - B38 Whidbey Island Dr Hat Island Wa 98206	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	7/31/23	
			23	COPPER	0.0749	mg/L	1.3	0.005	200.8	a	7/31/23	
046-44466	7/26/2023	31593N - 50 M Whidbey Dr Hat Island	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	7/31/23	
			23	COPPER	0.0671	mg/L	1.3	0.005	200.8	a	7/31/23	
046-44467	7/26/2023	31593N - 25 F Saratoga Dr Hat Island, Wa	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	7/31/23	
			23	COPPER	0.0501	mg/L	1.3	0.005	200.8	a	7/31/23	
046-44468	7/26/2023	31593N - M87 Olympic Dr, Hat Island Wa	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	7/31/23	
			23	COPPER	0.0582	mg/L	1.3	0.005	200.8	a	7/31/23	
046-44469	7/26/2023	31593N - F 102 Saratoga Ave. Hat Island, WA	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	7/31/23	
			23	COPPER	0.0111	mg/L	1.3	0.005	200.8	a	7/31/23	

**NOTES:**

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Specified Reporting Limit (SRL).

**These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.**

If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above.