



**Burlington, WA Corporate Laboratory (a)**  
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400  
**Bellingham, WA Microbiology (b)**  
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

**Portland, OR Microbiology/Chemistry (c)**  
 9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802  
**Corvallis, OR Microbiology/Chemistry (d)**  
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946  
**Bend, OR Microbiology (e)**  
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



OR NELAP 4072

## INORGANIC COMPOUNDS (IOC) REPORT

**Client Name:** Hat Island Community  
 3616 Colby Ave #335  
 Everett, WA 98201

**Reference Number:** 23-31674  
**Project:** Arsenic

**Date Collected:** 10/11/23 11:30  
**System ID Number:** 31593N  
**Lab Number:** 046-63154  
**Sample Location:** G Tank Pump house (Pre Distribution)  
**Sample Purpose:** C - Compliance  
**Sample Composition:** Single Source

**Approved by:** anp

**Authorized by:** 

Lawrence J Henderson, PhD  
 Director of Laboratories, Vice President

**Field ID:** Arsenic  
**System Group Type:** A  
**System Name:** HAT ISLAND COMMUNITY INC  
**County:** SNOHOMISH  
**Source Number:** 07  
**Multiple Sources:**  
**Date Received:** 10/12/23  
**Report Date:** 10/25/23  
**Sample Type:** A - After treatment  
**Sampled By:** Chris Inman  
**Sampler Phone:** 208-283-6443

**Sample Comment:**

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
4	<b>EPA Regulated</b> ARSENIC	<b>0.0079</b>	mg/L	0.001		<b>0.010</b>	bj	200.8	a	10/18/23	

**NOTES:**

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).  
 MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.  
 Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.  
 ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).  
 An \* in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.  
 If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above.